

Office of Station Officer
Fire and rescue Station
Thiruvananthapuram

No. C.558/2021

Date: 14.06.2021

FIRE FIGHTING SYSTEM INSPECTION REPORT

As per the request of S . JYOTHIS CHANDRAN & Mrs .L.SALITHA, Jyothis Plavilakom Kazhakuttom.P.O. Thiruvananthapuram - 695582, vide letter dated 10.06.2021, I have personally inspected the firefighting arrangements provided in the education buildings of Jyothis Central School, Menamkulam, Kazhakkootam, Trivandrum - 695582 with survey number: 397/1-1, 397/1-2-1,400/3, 400/4, 400/5-1, 400/2, 398/11 Ward-11, Village: Menamkulam Trivandrum and found the following arrangements,

The following arrangements were found

1. Fire Extinguisher
2. Hose Reel
3. Down Comer
4. Booster Pump 900LPM
5. Fire Brigade inlet
6. Over Head Tank 10000 Ltr Capacity

The above arrangements were tested and found working satisfactory at the time of inspection.



L. SALITHA
Principal

School Code : 75671
Jyothis Central School
Kazhakuttom P.O.
Thiruvananthapuram
Kerala - 695 582

Email: jyothisgroup@gmail.com

JYOTHIS CENTRAL SCHOOL
unit of Jyothis Charitable Educational Trust


S. Jyothis Chandran
Chairman & Managing Trustee




Station Officer
Fire and rescue Station
Thiruvananthapuram